

## Calculation of the separation distance according to ČSN EN 62305-3: 2006

Customer:	Gymnázium, SOŠ a VOŠ Nový Bydžov
Project:	Hromosvodní instalace
Project No.:	Ing. Lipovský

### Details on the project:

Determination of the minimum number of down conductors:

Length:	78,00 m
Width:	37,00 m

Circumference:	230,00 m
----------------	----------

Class of LPS selected

LPS III ▼

Minimum number of down conductors regarding lightning protection class

	Calcul. Value	Rounded to even number	Distances determined by class of LPS	Distances for calculated number of down conductors
Down conductors:	15,3333333	16	15,00 m	14,38 m